



**501 MILLER STREET
P O BOX 578
ANAHUAC, TEXAS 77514-0578**

SURFACE WATER TREATMENT TECHNIQUE: NON-ACUTE

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

The CITY OF ANAHUAC, PWS ID TX0360001, failed to meet the minimum treatment technique requirements for the month of FEBRUARY 2012. Specifically, our water system had

Violation List:

- Combined filter effluent turbidity readings above 1.0 NTU.

The CITY OF ANAHUAC has taken the following corrective actions to prevent a recurrence of the violations: **THE PLANT WAS REHABBED**

If you have questions regarding this matter, you may contact **SIDNEY BRADLEY** at **409-267-6681**.

Posted /Delivered on: **JUNE 26, 2018**
